

**Specification & Eligibility of Tenderer of Rechargeable Lead Acid Industrial Battery: 2V, 200AH @ 10HR**

- ❖ Tenderer's offered battery should be equivalent to the Rechargeable Lead Acid Industrial Battery model DC235S/4, and rating will be 2V, 200AH @ 10HR
- ❖ Warranty: 2(two) years from the time of installation.
- ❖ The Tenderer must submit catalogue in English along with the technical offer.
- ❖ Tenderer must mention the name of manufacturer and country of origin in the technical offer.
- ❖ Tenderer must submit manufacturer 's Test Certificate at the time of supply of the battery.
- ❖ Tenderer must submit Authorization Certificate from manufacturer or his authorized distributor along with the technical offer.
- ❖ In technical specification tenderer should declare that battery manufacturer will follow IEC60896-21/22, IEC 61427, DIN 43539-T5 and EUROBAT guideline.
- ❖ Installation, testing, and commissioning must be done by the tenderer at ERL site within the quoted price.
- ❖ The tenderer must submit the certificate of satisfaction from end-users regarding the performance of similar works.
- ❖ The tenderer must have minimum 5 (five) years of related experience.

A handwritten signature in black ink, appearing to be 'H. A. A.', is located in the lower right quadrant of the page.