Specification & Eligibility of Tenderer of Rechargeable Lead Acid Industrial Battery: 2V, 64AH @ 10HR

- Tenderer's offered battery should be equivalent to the Rechargeable Lead Acid Industrial Battery model JC105S/4, and rating will be 2V, 64AH @ 10HR
- Warranty: 2(two) years from the time of installation.
- The Tenderer must submit catalogue in English along with the technical offer.
- Tenderer must mention the name of manufacturer and country of origin in the technical offer.
- Tenderer must submit manufacturer 's Test Certificate at the time of supply of the battery.
- Tenderer must submit Authorization Certificate from manufacturer or his authorized distributor along with the technical offer.
- In technical specification tenderer should declare that battery manufacturer will follow IEC60896-21/22, IEC 61427, DIN 43539-T5 and EUROBAT guideline.
- Installation, testing, and commissioning must be done by the tenderer at ERL site within the quoted price.
- The tenderer must submit the certificate of satisfaction from end-users regarding the performance of similar works.
- The tenderer must have minimum 5 (five) years of related experience.